



Test Certificate no. 7432208355

In accordance with Clause 12 of the Standards Law, 1953

Details of order:

Name of customer : Jinan Mech Piping Technology Co.Ltd
Address : Jinan Meigui Zone, Pingyin, China 0250400
Date of order: : January 24, 2024

Description of sample:

The model tested: SCH 40
Manufacturer: Jinan Mech Piping Technology Co.Ltd
Country of manufacture: China

Sampling details:

Date of sampling: January 25, 2024 The sampler: SII Representative
The quantity in the sample: 10

Nature of test: A full test within the framework of Standards Mark supervision

Tested according to the following standard:
SI 5452 – "Testing of products for use in contact with drinking water", from August 2022 and amendment No. 1 from October 2023
Tested within the framework of Standards Mark supervision, license No. 111881

This document contains 6 pages
and may be used only in full

**The test results in this
document refer only to the
item that was tested**

**This document does not
constitute a license for
Standard Mark**

Test Conclusions:

The product complies with the Israeli standard SI 5452 (2022).
The results details are given on the inner pages.
The Rule of Decision policy of the laboratory is to use binary statement with guard band (w) equal to the Uncertainty (U) of measurement. Thus, providing specific risk with probability of false rejection not greater than 2.5% approximately.
Notes:
Dates of the test: 29/01/2024 – 22/08/2024
Exposure ratio in the test: 40,000 squared mm per liter.
For use at a temperature up to 60°C.

Name: Assaf Amram

Position: Head of water section

On: October 28, 2024

Signature:

Chemistry, Food and Water Branch, 42 Chaim Levanon St, Tel Aviv 6997701 Israel,

Tel: 972-3-6465138, Fax: 972-3-6465036, E-mail: for food: food@sii.org.il, for wine: wine@sii.org.il, for food contact materials: fcm@sii.org.il, for water: water@sii.org.il, www.sii.org.il